

CERTIFICATE

The company

DIMAS SA
2nd klm Argos-Nafplion
21200 ARGOS
GREECE

with the production site in

Argos

hereby receives the confirmation that the product/s

Solar collectors

of the type

SOL+20, SOL+23, SOL+25, SOL+29


conforms to

DIN EN 12975-1:2006-06

DIN EN 12975-2:2006-06

Specific CEN KEYMARK Scheme Rules for Solar Thermal Products version 11.04 (Edition: 2009-12)

and is granted the licence to use the marks



in conjunction with the Registration No. below.

Registration No.: 011-7S1493 F

This Certificate is valid until 2016-04-30.

Annex

to the Certificate with Registration No. 011-7S1493 F, dated 2011-04-13

Technical data

See data sheet, part of the test report of 2011-04-11

Note(s):

- The freeze resistance test according to DIN EN 12975-2, clause 5.8 was not necessary.
According to the manufacturer's declaration, the certified solar collectors may be used in frost exposed areas only in combination with appropriate frost protection mixtures.
- The optional impact resistance test according to DIN EN 12975-2, clause 5.10 was not carried out.

Testing laboratory / Inspection body

Universität Stuttgart
Institut für Thermodynamik und
Wärmetechnik
Pfaffenwaldring 6
70569 Stuttgart

Test report(s)

No. 10COL931, No. 10COL932, No. 10COL932Q,
No. 10COL932S dated 2011-04-11

628